



कार्यालय सिविल सर्जन  
करनाल-132001



फोन नं. 0184-2267796, 2267569 ईमेल: dhs.esknl@hry.nic.in

NO OBJECTION CERTIFICATE

Certify that the premises of Monfort World School-II, Kunjpura Knl has been inspected on dated 02.01.2025. The campus of the Institute has been found satisfactory from Sanitation & Hygiene point of view. This certificate is valid for one year from the date of issue

Dy. Civil Surgeon (School Health)  
Karnal


No. SHC/KNL/2025/184

Date:- 17/02/2025

A Copy is forwarded to the Monfort World School-II, Kunjpura Knl to his reference no. MWS-II/01/2024/9833 dated 10.12.2024 for information.

Dy. Civil Surgeon (School Health)  
Karnal

  
**Manager**  
**Montfort World School**  
**Kunjpura (Karnal)**

  
Headmistress  
Montfort World School-II  
Kunjpura, Karnal

Memo No:- 604

Date:- 29/01/2025

Certificate  
No: TC-13659

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : KNL/13056/1/2025 / Private	<b>Sample Details</b>	<b>Date &amp; Time</b>
Sender : Principal Montfort World School-II	Collected By	STAFF
Location : , VPO -Kunjapura,Karnal	Collection Date	28/01/2025 at 15:17
Sample Description : Drinking Water	Received at lab	28/01/2025 at 15:26
Latitude / Longitude : 76.979278 / 29.687083	Analysis Start Date	28/01/2025
	Analysis End Date	29/01/2025
	Sample Quantity	1000ML

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2022)
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :1984 (RA 2022)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) :1984 (RA 2018)
4	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part 4): 2021
5	Total Dissolved Solids @ 180°C ± 2°C	140	500 mg/l.	2000 mg/l.	IS 3025 (Part-16) : 2023
6	Total Hardness as CaCo3	90	200 mg/l.	600 mg/l.	IS 3025 (Part-21) : 2009 (RA 2023)
7	Calcium as Ca	20	75 mg/l.	200 mg/l.	IS 3025 (Part-40) :1991 (RA 2023)
8	Magnesium as Mg	9.6	30 mg/l.	100 mg/l.	IS 3025 (Part-46) (RA 2023)
9	Total Alkalinity	100	200 mg/l.	600 mg/l.	IS 3025 (Part-23) : 1986 (RA 2019)
10	Chloride as Cl	40	250 mg/l.	1000 mg/l.	IS 3025 (Part-32) :1988 (RA 2019)
11	Sulphate as So4	25	200 mg/l.	400 mg/l.	USEPA-8051:2017
12	Fluoride as F	0.190	1.0 mg/l.	1.5 mg/l.	APHA 24th Edition-4500F C
13	Iron as Fe	0.01	1.0 mg/l.	1.0 mg/l.	USEPA-8008:2017
14	Nitrate as No3	1.1	45 mg/l.	45 mg/l.	APHA 24th Edition -4500 NO3 D
15	pH @ 25°C	7.35	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 2022

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by: *Jyoti Kaur*

*Amit Kumar*  
AMIT KUMAR, CHIEF CHEMIST 29/01/25  
STATE WATER TESTING LABORATORY, KARNAL  
email:-chiefchemist@phedharyana.gov.in

*Jyoti Kaur*  
Manager  
Montfort World School  
Kunjapura (Karnal)

*Jyoti Kaur*  
Headmistress  
Montfort World School-II  
Kunjapura, Karnal